

# CERTIFICATE OF CONFORMITY

## N° 20.1253A

### 1. Applicant

Applicant : Mr. Patrick Copin  
Manufacturer : TRACTEL SAS – RD619 Saint-Hilaire-Sous-Romilly – BP38- 10102 ROMILLY-SUR-SEINE- France

### 2. Equipment

Type of equipment: Anchor device Type C EN 795:2012 and TS16415:2013  
Manufacturer and Trademark: **TRACTEL**  
Model: **TRAVSAFE™**                      References: **GS10 and SS10**

NB: This anchor device is not personal protective equipment (PPE) against falls from a height.

### 3. Description

<u>Main characteristics</u>	<u>Components</u>	<u>References</u>
• Span: single and multi, min. 5 m - max. 15 m	• Flexible anchor: Ref. GS10 : 1x19 Ø 8 mm wire double rope in galvanized steel	017311
• User: 5 people <100kg or 3 people <150kg	Ref. SS10 : 1x19 Ø 8 mm wire double rope in stainless steel	017301
• Flexible anchor line tension: 400 daN	• Terminal anchor	027588
• Direction of use: wall and floor	• Intermediate anchor	126435
• Turn: 90° internal and external	• Join ring	020875
• Angle of use: max. 15°	• Turn	074317
• Energy absorber: by ring absorber at each end of lifeline	• Mobile anchor	076149 or 076159
• This device has: joins, entry/exit line fitting		
• This device has no: flexible support fixed on anchor, no metallic material without evidence of durability		
• This device can be used with EN 360: BLOCFOR 5ESD; 6ESD; 1.8A ESD; 1.8B ESD; 10 ESD; 20 ESD; 20R ESD		
• This device can be used with EN 353-2: Stopfor K; Stopfor B		

### 4. Technical referential

The Anchor device Type C was assessed taking into account the provisions of technical specification TS 16415:2013 on anchor device type conforms to EN 795 of July 2012 to the exclusion of any other standard.

### 5. Conclusion

The Anchor device Type C, of trademark "**TRACTEL**", model "**TRAVSAFE™**" and references "**GS10 and SS10**" presented by TRACTEL, conforms to the requirements of the technical specification TS 16415 of January 2013.

08/07/2020

Head of the Testing and Certification  
Centre

  
Thollier  
Validation électronique

*This certificate includes one page. This certificate is edited in two original copies. No duplicate will be issued.*

*This type of equipment is not a Personal Protective Equipment against falls from height, the present certificate of conformity is not an EC type examination certificate delivered by a notified body.*